



City of Seattle Preliminary Assessment Report

June 02, 2010

This report represents a preliminary determination of project requirements from various city departments. The report is based on project characteristics that you identified on the Site Plan and the Preliminary Application Form, and on your Pre-Application Site Visit (PASV). The city's goal is to provide you with as much information and assistance as possible prior to your permit application submittal. This coordinated list of requirements and decisions is a reference for creating a more complete submittal package to reduce the need for correction cycles that delay permit approval. The information in this report can also be used to develop a Street Improvement Plan (SIP) application for submittal to SDOT (see SDOT Client Assistance Memos 2200, 2201, 2211, 2212, 2213, and 2214).

Note: A preliminary assessment is being conducted on all land use projects as well as new construction projects. If you have a building project associated with your land use project, the preliminary assessment will not be repeated on the building project.

The applicant assumes full responsibility for determining all permit requirements and infrastructure improvements per applicable sections of the Seattle Municipal Code and the City of Seattle's Right-of-Way Improvement manual.

- Street use permits are required for all work in the right-of-way (see SDOT Client Assistance Memo 2100).
- If street improvements are required, you must obtain all necessary permits from SDOT.
- If an SIP is required, SDOT must accept your 90% complete SIP before DPD construction intake (see Client Assistance Memos 2200, 2206, 2209, 2211, 2213, and 2214).

Project Summary			
AP/Project No.	3011357	Ground Disturbance	Y
Application Template	PRJ	PASV Required This Permit	Y
Application Type	DISCRETIONARY LAND USE ACTION	Date PASV Completed	05/24/10
Category	SINGLE FAMILY / DUPLEX	PASV Done Under Permit Remarks	
DPD Review Type	FULL C		
Address	2223 NE 127th St		
Location	5/20/10 CBC: INTAKE LEAD - PLEASE SEE ADDRESSING REVIEW COMMENT TAB FOR NOTES		
Zoning	SF7200	Applicant	JOHN ADAMS 2400 N 45TH ST SUITE 200 SEATTLE WA 98103 (206) 728-9500
King County APN	2126049301		
Permit Status	Initial Information Collected		
Description of Work	Subdivide parcel # 212604-9301 into four lots.	Applicant Email	johna@stuartsilks.com
		Linked AP/Project Nos.	
SDOT Project No			

For detailed zoning information, click the King County APN number above, or visit <http://web1.seattle.gov/dpd/parceldata/> to find zoning details about your address.

Pre-Application Site Visit (PASV) Report

Contact: Kathleen H Wilson, (206) 233-7932, Kathleen.Wilson@seattle.gov

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the DPD Site Development Team at (206) 684-8860.

Note: Any project application associated with the development site can utilize the results from this PASV if the application is accepted by DPD within 18 months of the above inspection date. After 18 months, the applicant must apply for another PASV. No extensions will be granted.

ECA Mapping Unit and Type

This project site appears to include the following ECAs and/or buffers:

Known slide

Riparian management area

Wetland

Flood prone

Existing ROW Conditions

NE 127TH ST

Street conditions:

Chip seal

Unimproved

Curb conditions:

No curb adjacent to site

A storm inlet does not appear to be located <350 ft from the site and prior to crossing a public right of way.

Potential Impacts to Seattle Parks Property

No parks property in vicinity

Tree Protection

Trees greater than 6 inches in diameter are present on the site but not shown on the site plan. Show the dripline of 1) **all** trees on the site, 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter and 3) **all** trees located in the adjacent ROW. Include common and scientific names for all trees shown. See Director's Rule 16-2008 and CAM 242.

Many very large trees

Per SMC 25.11 and DR 16-2008, exceptional trees may be located on the site. Clearly label all exceptional trees.

Inspectors Notes

This project is for a parcel subdivision into 4 lots, no construction activity is proposed at this time

Standard Submittal Requirements for Projects in an ECA

Provide a topographic survey with 2-foot contours on and within 25-feet of the property, stamped by a licensed land surveyor (see SMC 25.09.330A)

Show 100-foot riparian management area on plans

Note: No construction activity is allowed in the non-disturbance buffer area and limited development is allowed in the outer portion of the riparian management areas. Refer to SMC 25.09.200 for more information.

Site appears to have areas with wetland vegetation and/or seasonal or permanent saturation; the permit application should be routed to a DPD wetland specialist for further review. Whenever development is proposed within 100 feet of a wetland, the applicant is required to submit a Wetland Site Assessment Report prepared by a qualified wetlands professional that evaluates and identifies wetlands within 100 feet of the subject property line (see SMC 25.09.160). The method for preparing a wetland delineation report shall follow Director's Rule 19-2006, Requirements for Wetland Site Assessment Reports.

Site is located within an identified flood prone area regulated by SMC 25.09 as an ECA. The lowest floor elevation of any structure located in a flood-prone area shall be no less than 2 feet above the 100-year flood elevation. Refer to SMC 25.09.120 for the further details.

Seattle City Light Requirements

Contact: Ray Ramos, (206) 615-1193, ray.ramos@seattle.gov

Easements

SCL power easement is required. Property survey may be required at project's expense. Review for additional easements will be completed through the DPD land use application process.

SCL power easement over the property exists.

DPD Drainage Requirements

Contact: Michelle M Macias, (206) 684-3068, michelle.macias@seattle.gov

The following requirements are based on the current stormwater and side sewer codes. Major updates to these codes are expected in the fourth quarter of 2009.

Existing Public Drainage Infrastructure

Sanitary sewer main location: Onsite (Changes from SPU to KC Ownership)

Sanitary sewer main size: 8-inch

Drainage

The drainage point of discharge (SMC 22.805.020) is located at: On site (infiltration). Requires biologist approval.

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. Refer to CAM 531, Post Construction Soil Management. For projects with 5,000 square feet or more of new plus replaced impervious surface, a comprehensive drainage control plan and construction stormwater control plan shall be prepared by a licensed engineer.

All single-family residential projects shall implement green stormwater infrastructure (GSI) to the maximum extent feasible per SMC 22.805.030. Refer to CAMs 530-537 - Green Stormwater Infrastructure on Private Property. Refer to Director's Rule 19-2009 - Requirements for Green Stormwater Infrastructure to the Maximum Extent Feasible. Submit a Standard Drainage Control Plan for Single Family Projects that includes a GSI Calculator per DR 19-2009.

Wastewater

The wastewater point of discharge (SMC 21.16.070.B) is located at To Onsite Sewer Main with SPU approval..

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a King County Capacity Charge. Further information is available online at:

<http://www.kingcounty.gov/environment/wastewater/capacitycharge.aspx>

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge (DPD DR 3-2006/SPU DR 02-06 VII.H) is located at the following: Onsite (infiltration).

Side Sewer

A core tap is required for a public main located on private property.

Other Requirements

A buildover on an SPU facility is proposed (DPD DR 3-2006/SPU DR 02-06 VII E3 and DPD DR 2-2006/SPU DR 01-06 VII C4).

DPD Land Use Code Requirements

Contact: Naomi Henry, (206) 684-5223, naomi.henry@seattle.gov

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at DPD permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to DPD permit application intake.

NE 127TH ST

Grading to future ROW grade. See <http://www.seattle.gov/transportation/gradesheetintro.htm>

New structures must be designed to accommodate future right-of-way improvements. To ensure that driveways and pedestrian access points are designed to match these future street improvements, please use the Building Grade Calculator, which can be found at <http://www.seattle.gov/transportation/gradesheetintro.htm>

Because full street improvements are not being required for this project, or the project qualifies for a reduced street improvement, a no-protest agreement is required. This form can be found at http://www.seattle.gov/dpd/static/Covenant_Consenting_LID_LatestReleased_DPDS_006060.pdf

Land Use

Based on the project scope and/or location of environmentally critical areas on the development site, SEPA may be required. See CAM 208 for more details.

An arborist report is required. See CAM 242 for more detail.

Other Requirements

Based on the preliminary scope of the project, DPD recommends a presubmittal conference prior to submitting an application. Details for preparing and submitting a presubmittal conference request form can be found at our Web site (http://www.seattle.gov/dpd/Publications/Forms/Building_Permit/default.asp).

SDOT Requirements

Contact: Leo Kaarrekoski, leo.kaarrekoski@seattle.com

Based on the information provided at this time, it appears that no street improvements are **required**. All work in the right-of-way requires a permit. Therefore, if you are planning discretionary improvements you should contact SDOT as soon as possible. Be advised that it is the applicant's responsibility to seek guidance from SDOT Street Use should the scope of the project change, or should the applicant become aware of proposed construction in the ROW. Failure to contact SDOT at your earliest convenience could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SPU Requirements

Contact: Jennyfer Jacobsen, (206) 684-8766, JacobsJS@seattle.gov

Flow Control Compliance

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.020.E. For projects with 5,000 square feet or more of new and replaced impervious surface, a comprehensive drainage control plan shall be prepared by a licensed engineer.

Roadway projects with 7,000 square feet or more of land disturbing activity or 2,000 square feet or more of new plus replaced impervious surface must implement green stormwater infrastructure to infiltrate, disperse, and retain drainage water onsite to the maximum extent feasible without causing flooding, landslide, or erosion impacts per SMC 22.805.020.F. Refer to DR GSI to MEF and DR Vol.3.

Stormwater Treatment

No requirements

Water Availability

Contact: SPU Water

Your water availability assessment is in progress. System improvements may be required; the extent of those improvements will be sent to you on your Water Availability Certificate.

Other Requirements

- Two build-over agreements will be required with SPU and King County for this project. For a build-over agreement with SPU, please refer to CAM 507, Side Sewer Permits for Build-Over Agreements, for instructions to apply for a build-over review. New easements or relinquishing existing easements requires City Council action prior to building permit approval, and may take up to 18 months. Revisions to existing easements are sometime required for Construction Permits. For build-over with King County, please consult with King County.

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to DPD CAM 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or

www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to CAM 208 for information regarding the application requirements for a SEPA review and CAM 3000 for information regarding landmarks and historic preservation.

Applicant Next Steps

For questions on the permit application process, please contact the Applicant Services Center (ASC) at 206-684-8850.

1. Review the requirements in this report.
2. Use Client Assistance Memos (CAMs), checklists and standards, and 5 Steps for a Successful DPD Application Submittal (available on the DPD website) for additional information.
3. If a SIP is required, **DPD will not accept your application until your SIP application is screened at SDOT**. Allow a minimum of 5 days for screening after application submittal to SDOT.
4. Information on requirements for Electric Service Connection (RESC), electric service applications, guidelines and other services can be found on Seattle City Light's website (<http://www.seattle.gov/light/newconstruction/>). Contact an Electric Service Representative for your electrical service design and connection questions:
North of Denny Way (206) 615-0600
South of Denny Way (206) 386-4200
Large Commercial & Industrial (206) 233-7177
Service Applications (206) 233-APPS (2777)
5. If you have additional questions or need additional information, you may request a pre-submittal conference. Call (206) 684-8850 or go to DPD's website (http://www.seattle.gov/dpd/Publications/Forms/Building_Permit/default.asp).
6. When all issues have been addressed, you may schedule an intake appointment with DPD. **Please bring a copy of this report to your intake appointment.**

The requirements and determinations in this report are based on the details provided by the applicant on the preliminary application form and site plan submitted to DPD. If the scope of your proposed project changes before your DPD intake appointment or SDOT SIP application, the requirements in this report are subject to change. If there are municipal code and ordinance changes prior to your DPD intake, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.